ANA
LABORATORIES
130-B, HARDING AVE. BELLMAWR, NJ 08031
P.O. BOX 727 BELLMAWR, NJ 08099-0029
PHONE: 1-800-648-2625 or 856-931-0011
FAX: 856-931-5205
EMAIL: lab@analaboratories.com

Lab Number:	**S09M18456**
Customer I.D:	**AMTRAKTX**
Source:	**500 BASELINE**
Sample Date:	**12/22/2009**
Product Type:	**B-20**
Report Date:	**12/31/2009**

AMTRAK
ATTENTION:
TIM COOPER
400 SOUTH HOUSTON ST. STE. 100
DALLAS, TX 75202

TEST	DESCRIPTION	ASTM	SPECIFICATION	RESULT	UNITS
1)	Flash Point	D-93	**52 minimum**	**72**	degrees Celsius
2)	Water and Sediment	D-2709	**0.0500 maximum**	**<0.0010**	volume %
3)	Kinematic Viscosity @ 40 C	D-445	**1.9 - 4.1**	**3.19**	cSt
4)	Ash content	D-482	**0.01 maximum**	**0.003**	weight %
5)	Sulfur	D-5453	**15 maximum**	**9**	parts per million
6)	Copper Strip Corrosion	D-130	**No. 3 maximum**	**1a**	rating
7)	Cetane Index	D-976	**40 minimum**	**45.6**	
8)	Cloud Point	D-2500	**Report**	**-6**	degrees Celsius
9)	Carbon Residue 10 %	D-524	**0.3500 maximum**	**0.1010**	weight %
10)	Aromaticity	D-1319	**35 maximum**	**46.6 ****	volume %
11)	Acid Number	D-664	**0.3 maximum**	**0.12**	mg KOH/g
12)	Free Glycerin	D-6584	**Report**	**0.07**	volume %
13)	Total Glycerin	D-6584	**Report**	**0.07**	volume %
14)	Distillation Temperature 90%	D-86	**343 maximum**	**336**	degrees Celsius
15)	Biodiesel Content	D-7371	**6-20**	**17.4**	volume %
16)	Oxidation Stability	EN14112	**6 minimum**	**>10**	hours
17)	Lubricity	D-6079	**520 maximum**	**207**	microns

Comment: Result for Aromaticity is not with ASTM specifications.

For ANA LABORATORIES, INC.

ANA
LABORATORIES
130-B, HARDING AVE. BELLMAWR, NJ 08031
P.O. BOX 727 BELLMAWR, NJ 08099-0029
PHONE: 1-800-648-2625 or 856-931-0011
FAX: 856-931-5205
EMAIL: lab@analaboratories.com

Lab Number:	**S10B2441**
Customer I.D:	**AMTRAKTX**
Source:	**500 B20**
Sample Date:	**1/21/2010**
Product Type:	**B-20**
Report Date:	**2/12/2010**

AMTRAK
ATTENTION:
TIM COOPER
400 SOUTH HOUSTON ST. STE. 100
DALLAS, TX 75202

TEST	DESCRIPTION	ASTM	SPECIFICATION	RESULT	UNITS
1)	Flash Point	D-93	**52 minimum**	**74**	degrees Celsius
2)	Water and Sediment	D-2709	**0.0500 maximum**	**<0.0010**	volume %
3)	Kinematic Viscosity @ 40 C	D-445	**1.9 - 4.1**	**3.14**	cSt
4)	Ash content	D-482	**0.01 maximum**	**0.003**	weight %
5)	Sulfur	D-5453	**15 maximum**	**9**	parts per million
6)	Copper Strip Corrosion	D-130	**No. 3 maximum**	**1a**	rating
7)	Cetane Index	D-976	**40 minimum**	**53.3**	
8)	Cloud Point	D-2500	**Report**	**7**	degrees Celsius
9)	Carbon Residue 10 %	D-524	**0.3500 maximum**	**0.040**	weight %
10)	Aromaticity	D-1319	**35 maximum**	**31**	volume %
11)	Acid Number	D-664	**0.3 maximum**	**0.19**	mg KOH/g
12)	Free Glycerin	D-6584	**Report**	**0.00**	volume %
13)	Total Glycerin	D-6584	**Report**	**0.00**	volume %
14)	Distillation Temperature 90%	D-86	**343 maximum**	**331**	degrees Celsius
15)	Biodiesel Content	D-7371	**6-20**	**20**	volume %
16)	Oxidation Stability	EN14112	**6 minimum**	**>10**	hours
17)	Lubricity	D-6079	**520 maximum**	**195**	microns

Comment: Results are within specification. Please note, Cloud Point is only 7 C (44 F).

For ANA LABORATORIES, INC.

ANA
LABORATORIES
130-B, HARDING AVE. BELLMAWR, NJ 08031
P.O. BOX 727 BELLMAWR, NJ 08099-0029
PHONE: 1-800-648-2625 or 856-931-0011
FAX: 856-931-5205
EMAIL: lab@analaboratories.com

Lab Number:	**S10B9636**
Customer I.D:	**AMTRAKFTX**
Source:	**Fort Worth B-20**
Sample Date:	**2/9/2010**
Product Type:	**B-20**
Report Date:	**2/22/2010**

AMTRAK
ATTENTION:
TIM COOPER
400 SOUTH HOUSTON ST. STE. 100
DALLAS, TX 75202

TEST	DESCRIPTION	ASTM	SPECIFICATION	RESULT	UNITS
1)	Flash Point	D-93	**52 minimum**	**67**	degrees Celsius
2)	Water and Sediment	D-2709	**0.0500 maximum**	**<0.0010**	volume %
3)	Kinematic Viscosity @ 40 C	D-445	**1.9 - 4.1**	**3.14**	cSt
4)	Ash content	D-482	**0.01 maximum**	**0.003**	weight %
5)	Sulfur	D-5453	**15 maximum**	**9**	parts per million
6)	Copper Strip Corrosion	D-130	**No. 3 maximum**	**1a**	rating
7)	Cetane Index	D-976	**40 minimum**	**47.2**	
8)	Cloud Point	D-2500	**Report**	**-6**	degrees Celsius
9)	Carbon Residue 10 %	D-524	**0.3500 maximum**	**0.051**	weight %
10)	Aromaticity	D-1319	**35 maximum**	**24**	volume %
11)	Acid Number	D-664	**0.3 maximum**	**0.19**	mg KOH/g
12)	Free Glycerin	D-6584	**Report**	**0.00**	volume %
13)	Total Glycerin	D-6584	**Report**	**0.00**	volume %
14)	Distillation Temperature 90%	D-86	**343 maximum**	**333**	degrees Celsius
15)	Biodiesel Content	D-7371	**6-20**	**20**	volume %
16)	Oxidation Stability	EN14112	**6 minimum**	**>10**	hours
17)	Lubricity	D-6079	**520 maximum**	**212**	microns

Comment: Test results are within specification.

For ANA LABORATORIES, INC.

ANA
LABORATORIES
130-B, HARDING AVE. BELLMAWR, NJ 08031
P.O. BOX 727 BELLMAWR, NJ 08099-0029
PHONE: 1-800-648-2625 or 856-931-0011
FAX: 856-931-5205
EMAIL: lab@analaboratories.com

Lab Number:	**S10G17927**
Customer I.D:	**AMTRAKFTX**
Source:	**Fort Worth B-20**
Sample Date:	**7/27/2010**
Product Type:	**B-20**
Report Date:	**8/9/2010**

AMTRAK
ATTENTION:
TIM COOPER
400 SOUTH HOUSTON ST. STE. 100
DALLAS, TX 75202

TEST DESCRIPTION		ASTM	SPECIFICATION	RESULT	UNITS
1)	Flash Point	D-93	**52 minimum**	**73**	degrees Celsius
2)	Water and Sediment	D-2709	**0.0500 maximum**	**<0.0010**	volume %
3)	Kinematic Viscosity @ 40 C	D-445	**1.9 - 4.1**	**2.62**	cSt
4)	Ash content	D-482	**0.01 maximum**	**0.003**	weight %
5)	Sulfur	D-5453	**15 maximum**	**8**	parts per million
6)	Copper Strip Corrosion	D-130	**No. 3 maximum**	**1a**	rating
7)	Cetane Index	D-976	**40 minimum**	**46.4**	
8)	Cloud Point	D-2500	**Report**	**-6**	degrees Celsius
9)	Carbon Residue 10 %	D-524	**0.3500 maximum**	**0.052**	weight %
10)	Aromaticity	D-1319	**35 maximum**	**22**	volume %
11)	Acid Number	D-664	**0.3 maximum**	**0.17**	mg KOH/g
12)	Free Glycerin	D-6584	**Report**	**0.00**	volume %
13)	Total Glycerin	D-6584	**Report**	**0.00**	volume %
14)	Distillation Temperature 90%	D-86	**343 maximum**	**328**	degrees Celsius
15)	Biodiesel Content	D-7371	**6-20**	**19.9**	volume %
16)	Oxidation Stability	EN14112	**6 minimum**	**>10**	hours
17)	Lubricity	D-6079	**520 maximum**	**209**	microns

Comment: Test results are within specification.

For ANA LABORATORIES, INC.

ANA
LABORATORIES
130-B, HARDING AVE. BELLMAWR, NJ 08031
P.O. BOX 727 BELLMAWR, NJ 08099-0029
PHONE: 1-800-648-2625 or 856-931-0011
FAX: 856-931-5205
EMAIL: lab@analaboratories.com

Lab Number:	**S10H8698**
Customer I.D:	**AMTRAKFTX**
Source:	**Fort Worth B-20**
Sample Date:	**8/2/2010**
Product Type:	**B-20**
Report Date:	**9/7/2010**

AMTRAK
ATTENTION:
TIM COOPER
400 SOUTH HOUSTON ST. STE. 100
DALLAS, TX 75202

TEST	DESCRIPTION	ASTM	SPECIFICATION	RESULT	UNITS
1)	Flash Point	D-93	**52 minimum**	**67**	degrees Celsius
2)	Water and Sediment	D-2709	**0.0500 maximum**	**<0.0010**	volume %
3)	Kinematic Viscosity @ 40 C	D-445	**1.9 - 4.1**	**2.70**	cSt
4)	Ash content	D-482	**0.01 maximum**	**0.003**	weight %
5)	Sulfur	D-5453	**15 maximum**	**7**	parts per million
6)	Copper Strip Corrosion	D-130	**No. 3 maximum**	**1a**	rating
7)	Cetane Index	D-976	**40 minimum**	**47.0**	
8)	Cloud Point	D-2500	**Report**	**-5**	degrees Celsius
9)	Carbon Residue 10 %	D-524	**0.3500 maximum**	**0.072**	weight %
10)	Aromaticity	D-1319	**35 maximum**	**20**	volume %
11)	Acid Number	D-664	**0.3 maximum**	**0.20**	mg KOH/g
12)	Free Glycerin	D-6584	**Report**	**0.00**	volume %
13)	Total Glycerin	D-6584	**Report**	**0.00**	volume %
14)	Distillation Temperature 90%	D-86	**343 maximum**	**330**	degrees Celsius
15)	Biodiesel Content	D-7371	**6-20**	**20.0**	volume %
16)	Oxidation Stability	EN14112	**6 minimum**	**>10**	hours
17)	Lubricity	D-6079	**520 maximum**	**187**	microns

Comment: Test results are within specification.

For ANA LABORATORIES, INC.

130-B, HARDING AVE. BELLMAWR, NJ 08031
P.O. BOX 727 BELLMAWR, NJ 08099-0029
PHONE: 1-800-648-2625 or 856-931-0011
FAX: 856-931-5205
EMAIL: lab@analaboratories.com

Lab Number:	**S10J10382**
Customer I.D:	**AMTRAKFTX**
Source:	**500**
	FUEL
Sample Date:	**9/13/2010**
Product Type:	**FUEL**
Report Date:	**10/7/2010**

AMTRAK
ATTENTION:
TIM COOPER
400 SOUTH HOUSTON ST. STE. 100
DALLAS, TX 75202

TEST	DESCRIPTION	ASTM	SPECIFICATION	RESULT	UNITS
1)	Flash Point	D-93	**52 minimum**	**69**	degrees Celsius
2)	Water and Sediment	D-2709	**0.0500 maximum**	**<0.0010**	volume %
3)	Kinematic Viscosity @ 40 C	D-445	**1.9 - 4.1**	**2.44**	cSt
4)	Ash content	D-482	**0.01 maximum**	**0.003**	weight %
5)	Sulfur	D-5453	**15 maximum**	**6**	parts per million
6)	Copper Strip Corrosion	D-130	**No. 3 maximum**	**1a**	rating
7)	Cetane Index	D-976	**40 minimum**	**49.2**	
8)	Cloud Point	D-2500	**Report**	**-5**	degrees Celsius
9)	Carbon Residue 10 %	D-524	**0.3500 maximum**	**0.044**	weight %
10)	Aromaticity	D-1319	**35 maximum**	**20**	volume %
11)	Acid Number	D-664	**0.3 maximum**	**0.18**	mg KOH/g
12)	Free Glycerin	D-6584	**Report**	**0.00**	volume %
13)	Total Glycerin	D-6584	**Report**	**0.00**	volume %
14)	Distillation Temperature 90%	D-86	**343 maximum**	**327**	degrees Celsius
15)	Biodiesel Content	D-7371	**6-20**	**19.9**	volume %
16)	Oxidation Stability	EN14112	**6 minimum**	**>10**	hours
17)	Lubricity	D-6079	**520 maximum**	**182**	microns

Comment: Test results are within specification.

For ANA LABORATORIES, INC.

ANA LABORATORIES
130-B, HARDING AVE. BELLMAWR, NJ 08031
P.O. BOX 727 BELLMAWR, NJ 08099-0029
PHONE: 1-800-648-2625 or 856-931-0011
FAX: 856-931-5205
EMAIL: lab@analaboratories.com

Lab Number:	**S10K18234**
Customer I.D:	**AMTRAKFTX**
Source:	**500**
	FUEL
Sample Date:	**10/28/2010**
Product Type:	**FUEL**
Report Date:	**11/6/2010**

AMTRAK
ATTENTION:
TIM COOPER
400 SOUTH HOUSTON ST. STE. 100
DALLAS, TX 75202

TEST	DESCRIPTION	ASTM	SPECIFICATION	RESULT	UNITS
1)	Flash Point	D-93	**52 minimum**	**72**	degrees Celsius
2)	Water and Sediment	D-2709	**0.0500 maximum**	**<0.0010**	volume %
3)	Kinematic Viscosity @ 40 C	D-445	**1.9 - 4.1**	**2.78**	cSt
4)	Ash content	D-482	**0.01 maximum**	**0.003**	weight %
5)	Sulfur	D-5453	**15 maximum**	**6**	parts per million
6)	Copper Strip Corrosion	D-130	**No. 3 maximum**	**1a**	rating
7)	Cetane Index	D-976	**40 minimum**	**51**	
8)	Cloud Point	D-2500	**Report**	**27**	degrees Celsius
9)	Carbon Residue 10 %	D-524	**0.3500 maximum**	**0.104**	weight %
10)	Aromaticity	D-1319	**35 maximum**	**23**	volume %
11)	Acid Number	D-664	**0.3 maximum**	**0.22**	mg KOH/g
12)	Free Glycerin	D-6584	**Report**	**0.00**	volume %
13)	Total Glycerin	D-6584	**Report**	**0.00**	volume %
14)	Distillation Temperature 90%	D-86	**343 maximum**	**328**	degrees Celsius
15)	Biodiesel Content	D-7371	**6-20**	**20.6**	volume %
16)	Oxidation Stability	EN14112	**6 minimum**	**>10**	hours
17)	Lubricity	D-6079	**520 maximum**	**201**	microns

Comment: Test results are within specification.

For ANA LABORATORIES, INC.

ANA LABORATORIES
130-B, HARDING AVE. BELLMAWR, NJ 08031
P.O. BOX 727 BELLMAWR, NJ 08099-0029
PHONE: 1-800-648-2625 or 856-931-0011
FAX: 856-931-5205
EMAIL: lab@analaboratories.com

Lab Number:	**S10M8815**
Customer I.D:	**AMTRAKFTX**
Source:	**500**
	FUEL
Sample Date:	**12/8/2010**
Product Type:	**FUEL**
Report Date:	**12/23/2010**

AMTRAK
ATTENTION:
TIM COOPER
400 SOUTH HOUSTON ST. STE. 100
DALLAS, TX 75202

TEST	DESCRIPTION	ASTM	SPECIFICATION	RESULT	UNITS
1)	Flash Point	D-93	**52 minimum**	67	degrees Celsius
2)	Water and Sediment	D-2709	**0.0500 maximum**	<0.0010	volume %
3)	Kinematic Viscosity @ 40 C	D-445	**1.9 - 4.1**	**2.81**	cSt
4)	Ash content	D-482	**0.01 maximum**	**0.003**	weight %
5)	Sulfur	D-5453	**15 maximum**	**13**	parts per million
6)	Copper Strip Corrosion	D-130	**No. 3 maximum**	**1a**	rating
7)	Cetane Index	D-976	**40 minimum**	**49.5**	
8)	Cloud Point	D-2500	**Report**	**-5**	degrees Celsius
9)	Carbon Residue 10 %	D-524	**0.3500 maximum**	**0.040**	weight %
10)	Aromaticity	D-1319	**35 maximum**	**15**	volume %
11)	Acid Number	D-664	**0.3 maximum**	**0.18**	mg KOH/g
12)	Free Glycerin	D-6584	**Report**	**0.00**	volume %
13)	Total Glycerin	D-6584	**Report**	**0.00**	volume %
14)	Distillation Temperature 90%	D-86	**343 maximum**	**330**	degrees Celsius
15)	Biodiesel Content	D-7371	**6-20**	**19.5**	volume %
16)	Oxidation Stability	EN14112	**6 minimum**	**>10**	hours
17)	Lubricity	D-6079	**520 maximum**	**160**	microns

Comment: Test results are within specification.

For ANA LABORATORIES, INC.

ANA
LABORATORIES
130-B, HARDING AVE. BELLMAWR, NJ 08031
P.O. BOX 727 BELLMAWR, NJ 08099-0029
PHONE: 1-800-648-2625 or 856-931-0011
FAX: 856-931-5205
EMAIL: lab@analaboratories.com

Lab Number:	**S11B880**
Customer I.D:	**AMTRAKFTX**
Source:	**500**
	FUEL
Sample Date:	**1/27/2011**
Product Type:	**Bio-Diesel 20 %**
Report Date:	**2/25/2011**

AMTRAK
ATTENTION:
TIM COOPER
400 SOUTH HOUSTON ST. STE. 100
DALLAS, TX 75202

TEST	DESCRIPTION	ASTM	SPECIFICATION	RESULT	UNITS
1)	Flash Point	D-93	**52 minimum**	68	degrees Celsius
2)	Water and Sediment	D-2709	**0.0500 maximum**	**<0.0010**	volume %
3)	Kinematic Viscosity @ 40 C	D-445	**1.9 - 4.1**	**2.81**	cSt
4)	Ash content	D-482	**0.01 maximum**	**0.004**	weight %
5)	Sulfur	D-5453	**15 maximum**	**9**	parts per million
6)	Copper Strip Corrosion	D-130	**No. 3 maximum**	**1a**	rating
7)	Cetane Index	D-976	**40 minimum**	**49.1**	
8)	Cloud Point	D-2500	**Report**	-4	degrees Celsius
9)	Carbon Residue 10 %	D-524	**0.3500 maximum**	**0.074**	weight %
10)	Aromaticity	D-1319	**35 maximum**	**16**	volume %
11)	Acid Number	D-664	**0.3 maximum**	**0.21**	mg KOH/g
12)	Free Glycerin	D-6584	**Report**	**0.00**	volume %
13)	Total Glycerin	D-6584	**Report**	**0.00**	volume %
14)	Distillation Temperature 90%	D-86	**343 maximum**	**329**	degrees Celsius
15)	Biodiesel Content	D-7371	**6-20**	**20.8**	volume %
16)	Oxidation Stability	EN14112	**6 minimum**	**>10**	hours
17)	Lubricity	D-6079	**520 maximum**	**208**	microns

Comment: Test results are within specification.

For ANA LABORATORIES, INC.

ANA LABORATORIES
130-B, HARDING AVE. BELLMAWR, NJ 08031
P.O. BOX 727 BELLMAWR, NJ 08099-0029
PHONE: 1-800-648-2625 or 856-931-0011
FAX: 856-931-5205
EMAIL: lab@analaboratories.com

Lab Number:	**S11B19763**
Customer I.D:	**AMTRAKFTX**
Source:	**500**
	FUEL
Sample Date:	**2/22/2011**
Product Type:	**Bio-Diesel 20 %**
Report Date:	**3/8/2011**

AMTRAK
ATTENTION:
TIM COOPER
400 SOUTH HOUSTON ST. STE. 100
DALLAS, TX 75202

TEST	DESCRIPTION	ASTM	SPECIFICATION	RESULT	UNITS
1)	Flash Point	D-93	**52 minimum**	**71**	degrees Celsius
2)	Water and Sediment	D-2709	**0.0500 maximum**	**<0.0010**	volume %
3)	Kinematic Viscosity @ 40 C	D-445	**1.9 - 4.1**	**2.84**	cSt
4)	Ash content	D-482	**0.01 maximum**	**0.004**	weight %
5)	Sulfur	D-5453	**15 maximum**	**10**	parts per million
6)	Copper Strip Corrosion	D-130	**No. 3 maximum**	**1a**	rating
7)	Cetane Index	D-976	**40 minimum**	**48.3**	
8)	Cloud Point	D-2500	**Report**	**-4**	degrees Celsius
9)	Carbon Residue 10 %	D-524	**0.3500 maximum**	**0.048**	weight %
10)	Aromaticity	D-1319	**35 maximum**	**13**	volume %
11)	Acid Number	D-664	**0.3 maximum**	**0.20**	mg KOH/g
12)	Free Glycerin	D-6584	**Report**	**0.00**	volume %
13)	Total Glycerin	D-6584	**Report**	**0.00**	volume %
14)	Distillation Temperature 90%	D-86	**343 maximum**	**327**	degrees Celsius
15)	Biodiesel Content	D-7371	**6-20**	**19.0**	volume %
16)	Oxidation Stability	EN14112	**6 minimum**	**>10**	hours
17)	Lubricity	D-6079	**520 maximum**	**233**	microns

Comment: Test results are within specification.

For ANA LABORATORIES, INC.

ANA
LABORATORIES
130-B, HARDING AVE. BELLMAWR, NJ 08031
P.O. BOX 727 BELLMAWR, NJ 08099-0029
PHONE: 1-800-648-2625 or 856-931-0011
FAX: 856-931-5205
EMAIL: lab@analaboratories.com

Lab Number:	**S11D6748**
Customer I.D:	**AMTRAKFTX**
Source:	**500**
	FUEL
Sample Date:	**3/22/2011**
Product Type:	**Bio-Diesel 20 %**
Report Date:	**4/19/2011**

AMTRAK
ATTENTION:
TIM COOPER
400 SOUTH HOUSTON ST. STE. 100
DALLAS, TX 75202

TEST	DESCRIPTION	ASTM	SPECIFICATION	RESULT	UNITS
1)	Flash Point	D-93	**52 minimum**	**66**	degrees Celsius
2)	Water and Sediment	D-2709	**0.0500 maximum**	**<0.0010**	volume %
3)	Kinematic Viscosity @ 40 C	D-445	**1.9 - 4.1**	**2.94**	cSt
4)	Ash content	D-482	**0.01 maximum**	**0.004**	weight %
5)	Sulfur	D-5453	**15 maximum**	**9**	parts per million
6)	Copper Strip Corrosion	D-130	**No. 3 maximum**	**1a**	rating
7)	Cetane Index	D-976	**40 minimum**	**50.9**	
8)	Cloud Point	D-2500	**Report**	**-3**	degrees Celsius
9)	Carbon Residue 10 %	D-524	**0.3500 maximum**	**0.029**	weight %
10)	Aromaticity	D-1319	**35 maximum**	**13**	volume %
11)	Acid Number	D-664	**0.3 maximum**	**0.20**	mg KOH/g
12)	Free Glycerin	D-6584	**Report**	**0.00**	volume %
13)	Total Glycerin	D-6584	**Report**	**0.00**	volume %
14)	Distillation Temperature 90%	D-86	**343 maximum**	**326**	degrees Celsius
15)	Biodiesel Content	D-7371	**6-20**	**22.1**	volume %
16)	Oxidation Stability	EN14112	**6 minimum**	**>10**	hours
17)	Lubricity	D-6079	**520 maximum**	**208**	microns

Comment: Bio content is above the 20% maximum.

For ANA LABORATORIES, INC.

ANA
LABORATORIES
130-B, HARDING AVE. BELLMAWR, NJ 08031
P.O. BOX 727 BELLMAWR, NJ 08099-0029
PHONE: 1-800-648-2625 or 856-931-0011
FAX: 856-931-5205
EMAIL: lab@analaboratories.com

Lab Number:	**S11D7238**
Customer I.D:	**AMTRAKFTX**
Source:	**500**
	FUEL
Sample Date:	**4/6/2011**
Product Type:	**Bio-Diesel 20 %**
Report Date:	**4/19/2011**

AMTRAK
ATTENTION:
TIM COOPER
400 SOUTH HOUSTON ST. STE. 100
DALLAS, TX 75202

TEST	DESCRIPTION	ASTM	SPECIFICATION	RESULT	UNITS
1)	Flash Point	D-93	**52 minimum**	**71**	degrees Celsius
2)	Water and Sediment	D-2709	**0.0500 maximum**	**<0.0010**	volume %
3)	Kinematic Viscosity @ 40 C	D-445	**1.9 - 4.1**	**2.85**	cSt
4)	Ash content	D-482	**0.01 maximum**	**.005**	weight %
5)	Sulfur	D-5453	**15 maximum**	**11**	parts per million
6)	Copper Strip Corrosion	D-130	**No. 3 maximum**	**1a**	rating
7)	Cetane Index	D-976	**40 minimum**	**46.1**	
8)	Cloud Point	D-2500	**Report**	**-11**	degrees Celsius
9)	Carbon Residue 10 %	D-524	**0.3500 maximum**	**.062**	weight %
10)	Aromaticity	D-1319	**35 maximum**	**13**	volume %
11)	Acid Number	D-664	**0.3 maximum**	**0.20**	mg KOH/g
12)	Free Glycerin	D-6584	**Report**	**0.00**	volume %
13)	Total Glycerin	D-6584	**Report**	**0.00**	volume %
14)	Distillation Temperature 90%	D-86	**343 maximum**	**326**	degrees Celsius
15)	Biodiesel Content	D-7371	**6-20**	**9.3**	volume %
16)	Oxidation Stability	EN14112	**6 minimum**	**>10**	hours
17)	Lubricity	D-6079	**520 maximum**	**179**	microns

Comment: Bio content is above the 20% maximum.

For ANA LABORATORIES, INC.

ANA
LABORATORIES
130-B, HARDING AVE. BELLMAWR, NJ 08031
P.O. BOX 727 BELLMAWR, NJ 08099-0029
PHONE: 1-800-648-2625 or 856-931-0011
FAX: 856-931-5205
EMAIL: lab@analaboratories.com

Lab Number:	**S11E1513**
Customer I.D:	**AMTRAKFTX**
Source:	**500**
	FUEL
Sample Date:	**4/26/2011**
Product Type:	**Bio-Diesel 20 %**
Report Date:	**5/18/2011**

AMTRAK
ATTENTION:
TIM COOPER
400 SOUTH HOUSTON ST. STE. 100
DALLAS, TX 75202

TEST	DESCRIPTION	ASTM	SPECIFICATION	RESULT	UNITS
1)	Flash Point	D-93	**52 minimum**	**73**	degrees Celsius
2)	Water and Sediment	D-2709	**0.0500 maximum**	**<0.0010**	volume %
3)	Kinematic Viscosity @ 40 C	D-445	**1.9 - 4.1**	**2.89**	cSt
4)	Ash content	D-482	**0.01 maximum**	**0.005**	weight %
5)	Sulfur	D-5453	**15 maximum**	**4**	parts per million
6)	Copper Strip Corrosion	D-130	**No. 3 maximum**	**1a**	rating
7)	Cetane Index	D-976	**40 minimum**	**50.5**	
8)	Cloud Point	D-2500	**Report**	**-12**	degrees Celsius
9)	Carbon Residue 10 %	D-524	**0.3500 maximum**	**0.033**	weight %
10)	Aromaticity	D-1319	**35 maximum**	**14**	volume %
11)	Acid Number	D-664	**0.3 maximum**	**0.16**	mg KOH/g
12)	Free Glycerin	D-6584	**Report**	**0.00**	volume %
13)	Total Glycerin	D-6584	**Report**	**0.00**	volume %
14)	Distillation Temperature 90%	D-86	**343 maximum**	**327**	degrees Celsius
15)	Biodiesel Content	D-7371	**6-20**	**17.8**	volume %
16)	Oxidation Stability	EN14112	**6 minimum**	**>10**	hours
17)	Lubricity	D-6079	**520 maximum**	**171**	microns

Comment: All test results are within specifications.

For ANA LABORATORIES, INC.

ANA
LABORATORIES
130-B, HARDING AVE. BELLMAWR, NJ 08031
P.O. BOX 727 BELLMAWR, NJ 08099-0029
PHONE: 1-800-648-2625 or 856-931-0011
FAX: 856-931-5205
EMAIL: lab@analaboratories.com

Lab Number:	**S11E12257**
Customer I.D:	**AMTRAKFTX**
Source:	**500**
	FUEL
Sample Date:	**5/9/2011**
Product Type:	**Bio-Diesel 20 %**
Report Date:	**6/8/2011**

AMTRAK
ATTENTION:
TIM COOPER
400 SOUTH HOUSTON ST. STE. 100
DALLAS, TX 75202

TEST	DESCRIPTION	ASTM	SPECIFICATION	RESULT	UNITS
1)	Flash Point	D-93	**52 minimum**	**73**	degrees Celsius
2)	Water and Sediment	D-2709	**0.0500 maximum**	**<0.0010**	volume %
3)	Kinematic Viscosity @ 40 C	D-445	**1.9 - 4.1**	**2.76**	cSt
4)	Ash content	D-482	**0.01 maximum**	**0.005**	weight %
5)	Sulfur	D-5453	**15 maximum**	**6**	parts per million
6)	Copper Strip Corrosion	D-130	**No. 3 maximum**	**1a**	rating
7)	Cetane Index	D-976	**40 minimum**	**46.6**	
8)	Cloud Point	D-2500	**Report**	**-12**	degrees Celsius
9)	Carbon Residue 10 %	D-524	**0.3500 maximum**	**0.048**	weight %
10)	Aromaticity	D-1319	**35 maximum**	**15**	volume %
11)	Acid Number	D-664	**0.3 maximum**	**0.24**	mg KOH/g
12)	Free Glycerin	D-6584	**Report**	**0.00**	volume %
13)	Total Glycerin	D-6584	**Report**	**0.00**	volume %
14)	Distillation Temperature 90%	D-86	**343 maximum**	**324**	degrees Celsius
15)	Biodiesel Content	D-7371	**6-20**	**18.7**	volume %
16)	Oxidation Stability	EN14112	**6 minimum**	**>10**	hours
17)	Lubricity	D-6079	**520 maximum**	**199**	microns

Comment: All test results are within specifications.

For ANA LABORATORIES, INC.